



2033 HERITAGE PARK DR, OKLAHOMA CITY, OK 73120 | 1.800.822.1650

Polarized Light Microscopy Asbestos Analysis Report

QuanTEM Lab No. 324636	Client: QuanTEM Laboratories, LLC
Account Number: A000	Dee Ammerman
Date Received: 07/15/2020	
Received By: Christiana Younge	
Date Analyzed: 07/15/2020	Project: Sample Report
Analyzed By: Benjamin Hill	Project Location: 2033 Heritage Park Drive, OKC, OK
Methodology: EPA/600/R-93/116	Project Number: 1234.01

QuanTEM Sample ID	Client Sample ID	Composition	Color / Description	Asbestos (%)	Non-Asbestos Fiber (%)	Non Fibrous
001	FTM-1	Layered	Green Floor Tile	Asbestos Present Chrysotile 6	Cellulose <1	CaCO3 Vinyl
001a		Layered	Black Mastic	Asbestos Present Chrysotile 2	Cellulose <1	Tar
002	TSI-1	Homogeneous	White Pipe Insulation	Asbestos Present Chrysotile 20 Amosite 10	Glass Fiber 40	Gypsum CaCO3
003	FP-1	Homogeneous	Gold Vermiculite	Asbestos Present Actinolite/Tremolite <1	NA	Vermiculite
004	CT-1	Homogeneous	White Ceiling Texture	Asbestos Not Present	NA	CaCO3 Mica Paint
005	SV-1	Homogeneous	Red Sheet Vinyl	Asbestos Present Chrysotile 30	Cellulose 10 Glass Fiber <1	Vinyl CaCO3
006	WBS-1	Layered	White Texture	Asbestos Present Chrysotile 2	Cellulose 2	CaCO3 Paint

Unless otherwise noted, upon receipt the condition of the sample was acceptable for analysis.

QuanTEM is a NVLAP accredited PLM laboratory (Lab Code: 101959-0). This report relates only to the specific items tested. NVLAP accreditation applies only to analysis performed utilizing EPA/600/M4-82-020 and EPA/600/R-93/116 methods. This report may not be used to claim product endorsement by NVLAP or any agency of the US Government. This report may not be reproduced except in full, without the written approval of the laboratory.



2033 HERITAGE PARK DR, OKLAHOMA CITY, OK 73120 | 1.800.822.1650

Polarized Light Microscopy Asbestos Analysis Report

Quantem Lab No. 324636	Client: Quantem Laboratories, LLC
Account Number: A000	Dee Ammerman
Date Received: 07/15/2020	
Received By: Christiana Younge	
Date Analyzed: 07/15/2020	Project: Sample Report
Analyzed By: Benjamin Hill	Project Location: 2033 Heritage Park Drive, OKC, OK
Methodology: EPA/600/R-93/116	Project Number: 1234.01

Quantem Sample ID	Client Sample ID	Composition	Color / Description	Asbestos (%)	Non-Asbestos Fiber (%)	Non Fibrous
006a		Layered	White Joint Compound	Asbestos Present Chrysotile <1	Cellulose <1	CaCO3
006b		Layered	White Sheetrock	Asbestos Not Present	Cellulose 10 Glass Fiber <1	Gypsum
007	RF-1	Homogeneous	Black Shingle	Asbestos Not Present	Glass Fiber 60	Tar Sand
008	AS-1	Homogeneous	Gray Transite	Asbestos Present Chrysotile 30 Crocidolite 10	Cellulose 5	CaCO3

Benjamin Hill

Benjamin Hill, Laboratory Analyst

7/15/2020

Date of Report

Unless otherwise noted, upon receipt the condition of the sample was acceptable for analysis.

Quantem is a NVLAP accredited PLM laboratory (Lab Code: 101959-0). This report relates only to the specific items tested. NVLAP accreditation applies only to analysis performed utilizing EPA/600/M4-82-020 and EPA/600/R-93/116 methods. This report may not be used to claim product endorsement by NVLAP or any agency of the US Government. This report may not be reproduced except in full, without the written approval of the laboratory.